

Project Name:			
Project Name: Location:		Approvale	
Engineer:		Approval:	
Submitted to:		Date: Construction:	
Submitted by:			
Reference:		Unit #:	
Reference.		Drawing #:	
<u>Performance</u>			
Indoor Unit Model No:	Ducted	Indoor Unit Type:	
Outdoor Unit Model No:	RXYQ96PATJ	Condensing Unit Type:	8-Ton VRV-III Heat Pump
Cooling Capacity (Btu/hr):	92000	O a a l'a sa Massaissa I	Indoor: 80°F DB/67°F WB
Sensible Capacity (Btu/hr):	0	Cooling Nominal	Outdoor: 95°F DB/75°F WB
Cooling Input Power (kW):		Conditions	Water Cooled:
Cooling EER (Btu/hr / kW):	11.1		Indoor: 47°F DB/43°F WB
SEER:	N/A	Heating Nominal	Outdoor: 47°F DB/43°F WB
Heating Capacity (Btu/hr):	103000	Conditions	Water Cooled:
Heating Input Power (kW):		Nominal Piping Length	25
Heating COP (Btu/hr / Btu/hr):	3.3	Nominal Height Separation	0
HSPF:	N/A	Nominal Water Flow Rate	
Indoor Unit Details			21/2
Power Supply (V/Hz/Ph:)	N/A	Airflow Rate (CFM wet coil)	N/A
Power Supply Connections:		Moisture Removal (pt/h):	
Min. Circuit Amps MCA (A):		Gas Pipe Connection (inch):	
Max. Fusible Amps MFA (A):		Liquid Pipe Connection (inch	
Dimensions (HxWxD):	N/A	Condensate Connection (incl	,
Panel (HxWxD):	N/A	Sound Pressure Level (dBA)	<u>:</u>
Net Weight (lbs):		Sound Power Level (dBA):	
Weight with Panel (lbs):		Nominal External Static Pres	
		Max Ext Static Pressure (inH	20)
Condensing Unit Details			
Power Supply (V/Hz/Ph):	208-230/60/3ph	Airflow Rate (CFM):	6530
Power Supply Connections:	L1, L2, L3 Ground	Gas Pipe Connection (inch):	7/8
Min. Circuit Amps MCA (A):	36.1	Liquid Pipe Connection (inch	): 3/8
Max. Fusible Amps MFA (A):	50	H/L Pressure Connection (in	ch):
Max. Starting Current MSC(A):	131	H/L Equalizing Connection (in	nch):
Rated Load Amps RLA (A):	7.6+16.8	Water Inlet Connection (inch	FPT):
Total Overcurrent Amps (A):	54.5	Water Outlet Connection (inc	h FPT):
Dimensions (HxWxD):	66-1/8x36-5/8x30-1/8	Condensate Drain Outlet (inc	ch FPS):
Net Weight (lbs):	560	Sound Pressure Level (dBA)	58
Compressor Type:	Inverter	Sound Power Level (dBA):	
Capacity Control Range (%):	20 - 100	Unit Heat Rejection (kW):	
Capacity Index Limit:	57.6 - 124.5 (130%)	Max. No. of Indoor Units:	16
System Details			
Refrigerant Type:	R-410A	Cooling Operation Range (°F	<del>5</del> ): 23 - 110
			,
	19.8	Cooling Range w/Battle (°F):	
Holding Refrigerant Charge (lbs):	19.8 install data	Cooling Range w/Baffle (°F): Heating Operation Range (°F)	F): 0 - 77 / -4 - 60
Holding Refrigerant Charge (lbs): Additional Charge (oz/ft):	19.8 install data	Heating Operation Range (°F	
Holding Refrigerant Charge (lbs): Additional Charge (oz/ft): Pre-charge Piping (Length ft):	install data	Heating Operation Range (°F): Heating Range w/Baffle (°F):	
Holding Refrigerant Charge (lbs): Additional Charge (oz/ft):		Heating Operation Range (°F	<del>-</del> ):




Project Name:		
Location:	Approval:	
Engineer:	Date:	
Submitted to:	Construction:	
Submitted by:	Unit #:	
Reference:	Drawing #:	





Project Name:	
Location:	Approval:
Engineer:	Date:
Submitted to:	Construction:
Submitted by:	Unit #:
Reference:	Drawing #:

#### **Dimensional Drawing - Condensing Unit**



Daikin AC (Americas), Inc., 1645 Wallace Drive - Suite 110, Carrollton, TX 75006



Project Name:		
Location:	Approval:	
Engineer:	Date:	
Submitted to:	Construction:	
Submitted by:	Unit #:	
Reference:	Drawing #:	

#### **Notes**

Std U.S. Warranty: 6yrs Compressor, 1yrs Parts, 1yr Limited Labor